

From Assistant Divisional Fire Officer/Fire Station Officer
MC NARNAUL

To M/s SARASWATI PUBLIC SCHOOL, BHOJAWAS PO- AKBARPUR, TEH- NANGAL
CHOUDHARY, DISTT. MAHENDERGARH

Memo No. FS/2023/65 dated : 03/10/2023

Subject: Renewal of Fire Safety Certificate 15 mtrs. and Above height from the fire Safety Point of the Group B-Educational Building at NEAR BUS STAND BHOJAWAS , TEH- NANGAL CH DISTT. MAHENDERGARH of SARASWATI PUBLIC SCHOOL

Reference to you online No 120762323000021 dated 26/09/2023 on the subject cited above.

Tower Name	Floor Detail	Height	Ground Co
SARASWATI PUBLIC SCHOOL	G+2 ONLY	10.05 mtrs	1162.144 S
Basement Level	Basement Area	Remarks	
NA	NA	NA	

Your site for the Renewal of the Fire Safety Certificate has been inspected by the Team of Fire Station Officers, NARNAUL from fire safety Point of View. The means of escape and Fire Protection system were checked and the National Building Code of India, Part- IV guidelines.

In view of the satisfactory fire protection system / arrangement mentioned as above, this office has no objection occupation from the Fire Safety point of view, with the following conditions:-

- 1) The owner/occupier shall keep duly trained Fire Staff in all three shifts.
- 2) The Fire Protection System tested during inspection shall be maintained properly & always should be in good condition.
- 3) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, to be taken as per rules against you.
- 4) You are directed to apply for Renewal of Fire Safety Certificate in future before 2 month of expiry of your Fire Certificate.
- 5) The open set back area is not checked at our end as it shall be checked by concerned building department.
- 6) The owner/occupier shall strictly follow the other applicable rules/ regulations/ byelaws laid down regarding fire system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per 30,31 & 47 of fire & Emergency Services Act 2022.
- 7) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and photography evidence to be kept as a record which shall be produced at the time of next Renewal; Officials/Residents should be mentioned in the drill.
- 8) If the Infringements of Byelaws remains un-noticed the Authority reserves the right to amend the Fire Safety Certificate and when any such Infringements comes to notice after giving an opportunity of being heard and the Authority stand Indemnified against any claim on this account.
- 9) The owner or occupier of the building shall give a self-declaration certificate annually to the effect that the fire system installed in his building is working in good condition and there is no addition/alteration in the building. The Officer may randomly check such building. In case there is any addition/alteration beyond permissible limits under Haryana Building Code, 2017, the fire safety certificate shall cease to exist and the owner shall apply for approved revised Fire Fighting Scheme as per the provisions of section 18.

The above Renewal of Fire Safety Certificate is valid for Three year from the date of issue of this letter Apply for renewal of the same well in time shall be the responsibility of owner/occupier.


Principal
Saraswati Public School
Bhojawas (M/Garh)